



## On Site Instructions for replacing the controller panel

Ask your electrician to replace the panel using following instructions:

1. Write down your settings and Unplug the unit
2. Unplug FCT and pH/ORP Probes and undo the Molex connector



3. Using Panel Hinge Tool remove front panel and control card from mounting box.



4. Replace the panel with new one
5. Plug in probes and connect Molex connector
6. Close the panel and turn on the controller
7. Input the correct settings and controller starts working